



HOSHIZAKI AMERICA, INC.

SERVICE BULLETIN

SB25-0011

October 28, 2025

Page 1 of 1

Subject: TXV 4A3493-01 and 4A4493-01 obsolete

We have been informed that expansion valves **4A3493-01** and **4A4493-01** have been made **obsolete** by the manufacturer.

Please note that the **new valves differ in physical design**. Therefore, when replacing either of these valves, it will also be necessary to order the **TXV cover (P/N 4A7679-01)**.

As a reminder, the **filter drier must be replaced** any time the sealed refrigeration system is opened. Be sure to order the correct drier specified for your model.

Obsolete number	New numbers
TXV 4A3493-01	TXV 4A7764-02
	Cover 4A7679-01
TXV 4A4493-01	TXV 4A7764-03
	Cover 4A7679-01

If you have any questions concerning this change, please contact the Technical Support Department at tech-support@hoshizaki.com or 1-800-233-1940.