



HOSHIZAKI AMERICA, INC.

SERVICE BULLETIN

SB99-0019R1

June 9, 2006

Page 1 of 2

SUBJECT: Non-Hoshizaki Remote Condenser Approvals and Heat Reclaim Devices

NOTE: This bulletin replaces SB90-0003R and SB99-0019

Hoshizaki is presently working with several manufacturers of remote condensers. Any account which is interested in purchasing a non-Hoshizaki condenser for use with our equipment must get prior approval through the Hoshizaki Technical Support Department. Hoshizaki will not warrant equipment that is connected to a condenser which has not received prior approval.

It is the Distributors responsibility to hold all orders received for remote icemakers (without a Hoshizaki condenser) until an approval is verified through Technical Support. NOTE: This means, Distributors selling Hoshizaki icemakers with a non-Hoshizaki condenser should contact the Technical Support Department to receive approval verification. One application is required per location. There are NO blanket approvals.

Each remote condenser manufacturer must complete the attached application, form number SB99-0019-A and return it to the Hoshizaki Technical Support Department. It may be faxed or sent to the following:

Hoshizaki Technical Support Department
Hoshizaki America, Inc.
618 Hwy. 74 South
Peachtree City, GA 30269
Fax# 404-487-3360 or 800-843-1056

When received the application will be reviewed, a decision made, and an answer returned to the condenser manufacturer. The condenser manufacturer will use the approved application to acquire the Hoshizaki head master from the local distributor.

It is imperative that this procedure is followed to assure that NO Hoshizaki unit is installed on an improperly sized remote condenser.



In addition to properly sizing non-OEM condensers, Hoshizaki also requires that all ice machines and condensers are matched properly. New models may have different efficiency ratings and can not be used with older Hoshizaki remote condensers. Mis-matched applications will affect the operation and warranty coverage of the system.

Note: Competitors remote condensers will not be approved as part of the non-OEM condenser approval procedure.

Heat Reclaim Devices

Due to many varieties of heat reclaim devices and the obvious problems which could arise through "Field Re-Engineering" of the equipment. Hoshizaki does not approve the use of heat reclaiming devices. Using said devices would effect unit operation and void Hoshizaki's parts and labor warranty.

NON-HOSHIZAKI CONDENSER APPLICATION SB99-0019R1-A

SB99-0019R1**June 9, 2006****Page 2 of 2**APPLICANT

Company Name _____
 Street Address _____
 City _____ State _____ Zip _____
 Telephone _____ Contact Name _____

Job Location _____
 Street Address _____
 City _____ State _____ Zip _____

Hoshizaki equipment to be used: Refrigerant tubing length (if available)
 Model # 1. _____ 4. _____ Vertical Run
 2. _____ 5. _____ Horizontal Run
 3. _____ 6. _____ Total Run

CONDENSER MANUFACTURER

Name _____ FAX # _____
 Telephone _____ Contact Name _____
 Condenser Model # _____
 Condenser Circuiting: Single Circuit _____ Dual Circuit _____ Multi-Circuit _____

Condenser Heat of Rejection BTU/Hour:

by Model #:	<u>MODEL</u>	<u>CHR-BTU / HR</u>	<u>FIGURED AT</u>	Ratings must be
_____	_____	_____	_____ T.D.	within \pm 5% of
_____	_____	_____	_____ T.D.	specifications
_____	_____	_____	_____ T.D.	

Condenser Refrigerant Required:

<u>TYPE</u>	<u>WEIGHT</u>	<u>CPR Required</u> <u>(YES or NO)</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____

Condenser Volume in Cubic Inches:

by Model #:	<u>MODEL</u>	<u>CUBIC INCH</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____

* On any line set over 66 feet, add a 1/2 oz. of the proper refrigerant for each foot. Other specifications to be met are as follows. The maximum line drop when the condenser is installed below the unit head is 10 feet. The maximum vertical line run when the condenser is mounted above the unit head is 33 feet. The maximum overall line set length is 100 feet. These measurements are from fitting to fitting. Exceeding these maximum limitations will affect the warranty coverage.

RETURN THIS APPLICATION TO:

Hoshizaki America, Inc. FAX # 1-800-843-1056
 Attn: Technical Support Department
 618 Hwy. 74 South
 Peachtree City, GA 30269

* After reviewing the data, applicant will be notified by Hoshizaki of approval or denial reasons and any special installation requirements.

APPLICANT SIGNATURE : _____ DATE : _____

FOR HOSHIZAKI USE ONLY

Approved by: _____ Date: _____
 Denied by: _____ Date: _____
 Reason for denial: _____

